

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client : Materialised 19 Heath Ro Blakehurst N		Test Number Issue Date Print Date Order Numbe	: 21/03/201 : 21/03/201	17
Sample Description	Clients Ref : "Good Night" Blind fabric, woven coated Colour : White End Use : Blind Fabric Nominal Composition : 100% Polyester Nominal Mass per Unit Area/Density : 420g/m	n2		
1530.2-1993	Methods for Fire Tests on Building Materials, Cor Part 2: Test for Flammability of Materials	mponents and Structu	res.	
	Date Tested		17/03/2017	
	Flammability Index		8	
		Length	Width	
	Spread Factor	6	7	
	Heat Factor	1	1	
	Maximum height (d)			
	Mean	5.7	6.0	
		5.7 9.1	6.0 10.5	%
	Mean			%
	Mean Coefficient of Variation			% °C.min
	Mean Coefficient of Variation Heat (a)	9.1	10.5	
	Mean Coefficient of Variation Heat (a) Mean	9.1	10.5	°C.min

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.



MANAGING DIRECTOR