AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240. North Melbourne. Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Materialised Pty Ltd

> 19 Heath Road Blakehurst NSW 2221

15-001199 Test Number : **Issue Date** 31/03/2015

Print Date 31/03/2015 Order Number:

29735

Clients Ref: **Sample Description**

> Woven backcoated fabric Colour: Beige End Use: Drapery

Nominal Composition: 100% Polyester

"Palazzo"

AS 1530.2-1993

Methods for fire tests on building materials, components and structures.

Part 2: Test for flammability of materials

Date Tested		30/03/2015	
Flammability Index		5	
	Length	Width	
Spread Factor	4	3	
Heat Factor	1	1	
Maximum height (d) Mean	40	4.4	
Coefficient of Variation	4.9 64.2	4.4	%
Heat (a)	04.2	40.7	%
Mean	3.2	2.6	°C.min
Coefficient of Variation	107.0	55.6	%

Observation Propagated smoke

Number of Specimens Tested

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

19806 3787 Page 1 of 1

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

Chemical Testing - Mechanical Testino

Performance & Approvals Testing

Accreditation No 983 Accreditation No. 985

: Accreditation No



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertise the Managing Director of AWTA Ltd.

9

IAEL A. JACKSON B.Sc.(Hons)

9